



2No 1win socket outlets, with 4No "Type F" 10No outlet power strip for radio equipment (Detail to be agreed with Hyphen)

Power supply to security panel.

2No 1win socket outlets with 2x2.1a USB charging outlets per socket. Socket outlets to be mounted above work top. AV HDMI faceplates and link cable in conduit. Socket outlet @450mm AFFL for fridge. desk. Hyphen to confirm mounting heights.

Conduits rise up to meet cable tray network at high level.

Recessed floor box with 2No twin surge suppressed socket outlets.

Conduits rise up to meet cable tray network at high level.

Conduits rise up to meet cable tray network at high level.

4No 2x25mm Galvanised steel conduits buried in floor screed.

Fused connection supply for facade swoosh signage lighting (Location tbc).

**ARCADE**

2No Twin socket outlets with 2x2.1a USB charging outlets per socket.

Sockets outlets mounted above worktop.

Power requirements to lift by manufacturer.

Main IT network cabinet within service cupboard 19" 42U network cabinet to NIKE NFS specification populated with 3x24 way port patch panels, 3x6 way power distribution units MK commando 32A 2P&E socket connection rack power supply.

Landlord to recondition existing distribution panel inline with reconditioning works to air handling plant.

1000 x 500

NEW LIFT

HW and Electric Room

H4

30,21 m<sup>2</sup>

H3

28,94 m<sup>2</sup>

H2

50,91 m<sup>2</sup>

H1

229,50 m<sup>2</sup>

GANG

44,59 m<sup>2</sup>

GITTERRENNWANDE

6,00

2,20

STOCK AREA

NIKE PLANT ZONE

MOBILE VAS TABLE  
CALL OFF 1A803

18F6

18F6

18F6

10F3

VAS

18F6

18F6

21F2  
21F3  
21F4  
17F2

